



Member of the FM Global Group

Nov. 20, 2008

Product Alert

Clarke Fire Protection Products, Inc. (Clarke UK, Ltd.) Initiates Diesel Engine Fire Pump Driver Inspection Campaign

Clarke Fire Protection Products Inc. has advised FM Approvals of the following:

Clarke UK Ltd, which prepares diesel engines for use on sprinkler pumps, indicates there is a possible latent manufacturing defect in John Deere 4045TF 4 cylinder turbo charged diesels engines.

For more information about the inspection campaign, please visit www.clarkefire.com and its news page at <http://www.clarkefire.com/Public/default.aspx?pid=355>.